



Government Of West Bengal
Office Of The Divisional Fire Officer, Purba Bardhaman
West Bengal Fire & Emergency Services
Bhangakhuti, Purba Burdwan, P.O.:- Rajbati, Pin :- 713104

Memo no.:IND/WB/FES/20192020/51239

Date: 15-03-2021

From:

Divisional Fire Officer, Purba Bardhaman
West Bengal Fire & Emergency Services

To: Nutanhat Teachers Training Institute.

Vill, P.O Nutanhat, Taluk Mongalkot, Plot no. 472, 480, 1113, Kh. no. 1005, 1223, P.S mongalkote, Dist. Purba Bardhaman, Pin 713147.

Sub: Fire Safety Certificate for occupancy of an existing construction of G+II Storied building under group educational at the premises no. Vill & PO :- Nutanhat , Taluk – Mongalkot , Plot No :- 472 , 480 , 1113 , Kh. No :- 1005 , 1223 , Mongolkote PS , Dist :- Purba Bardhaman , Pin :- 713147. for issuance of Fire Safety Certificate against online application no :- 0125189210300013

This is in reference to your application no. 0125189210300013 dated 28-02-2021 regarding the Fire Safety Certificate for occupancy of an existing construction of G+II Storied building under group educational at the premises no. Vill & PO :- Nutanhat , Taluk – Mongalkot , Plot No :- 472 , 480 , 1113 , Kh. No :- 1005 , 1223 , Mongolkote PS , Dist :- Purba Bardhaman , Pin :- 713147. for issuance of Fire Safety Certificate against online application no :- 0125189210300013

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

This is in reference to your Application No. 0125189210300013 , regarding issuance of Fire Safety Certificate for the occupancy of an existing construction of G+II Storied building under group educational at the premises no. Vill & PO :- Nutanhat , Taluk – Mongalkot , Plot No :- 472 , 480 , 1113 , Kh. No :- 1005 , 1223 , Mongolkote PS , Dist :- Purba Bardhaman , Pin :- 713147.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

The following conditions shall be enforced :-

CONDITION APPLIED

1. Maintenance/checking /testing of all fire safety installations shall be checked time to time.
2. Any nominated officer of this Deptt. Shall enter and inspect the building at any time between sunrise to sunset for ascertaining the contravention if any of Fire prevention and fire safety measures.
3. Good house keeping should be always to be maintained.
4. Mock Drill must be performed twice in a year and recorded properly.
5. To up-keep the Fire Safety Measures of the aforesaid building the following safety measures are to be incorporated.
6. Driveway must be free of any type of obstruction for easy movement of Fire Appliances.
- 7.No parking will be allowed on the Driveway.
8. The interior finish decoration of the building shall be made with low flame spread material confirming to the I.S. Specification.
9. To eliminate risk of fire hazards, good house-keeping both for inside and outside of the building shall be strictly maintained.
10. Existing Electrical wiring of the hole building shall have to be carefully checked for any wear and tear in them , particularly lines above false ceiling and ducts.
11. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the building.
12. The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.
13. Mock Fire practice and Evacuation Drill shall be performed periodically with participants of all the occupants of the building.
14. A crew of trained Fire Man under an experience officer shall be maintained round the clock for safety of the building.
15. First-Aid Fire Fighting system shall be provided as per I.S. specification.
16. Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building to keep them in perfectly good working condition at all the times.
17. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. conduit pipes continuously bonded with the earth.
18. Electrical ducts shall be sealed vertically and horizontally at each floor level by fire resisting materials.
19. The Fire Safety Audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.
20. Violation of any recommendations which issued from this office previously this fire safety certificate shall be treated as cancelled.

This certificate shall remain valid upto Three years as per existing Govt. Rule.

Signature valid

Signed by: NITAI CHITTOPADHYAY
Reason: Approved
Location: West Bengal
Date: 15-Mar-2024 12:37:35

Divisional Fire Officer, Purba Bardhaman
West Bengal Fire & Emergency Services